

OHIO TOWNSHIP SANITARY AUTHORITY  
MINUTES FROM THE SEPTEMBER 6, 2012 REGULAR MEETING

The Chairman called the Regular Meeting of the Ohio Township Sanitary Authority to order at the Ohio Township Municipal Building at 7:00 p.m. Present were: Dennis Coyle, Jeff Ciaramella, Herb Hartle and John Sullivan.

COMMENTS FROM THE CITIZENS – Mr. Orlando Robbbaro (519 Duff Road) & Mr. Bruce Robbbaro (418 Duff Road) spoke about the tap-in form. They had questions about the different noted amounts between the letter and the form and the process steps that need to be taken.

APPROVAL OF MINUTES – Mr. Hartle made a motion, seconded by Mr. Sullivan, approving the minutes as posted. The motion carried unanimously.

TREASURER'S REPORT & NVOICES DUE FOR PAYMENT – Mr. Sullivan made a motion, seconded by Mr. Ciaramella, approving the treasurer's report and regular invoices due for payment in the amount of \$51,132.91. The motion carried unanimously.

COMMUNICATIONS – None.

NEW BUSINESS – Mr. Coyle reported we need a motion to accept Resolution No. 5-12. This is a Resolution Authorizing the Release of existing tenant security deposits currently held in escrow back to the landlord. Mr. Hartle made a motion, seconded by Mr. Ciaramella and the motion passed.

ENGINEER'S REPORT – Mr. Evans reported that the DMR for July for the Kilbuck Run STP in compliance. The DMR for July for the Windy Knoll STP had a violation for Total Suspended Solids on the Weekly Average. CWM should offer a reason for this occurrence.

Lateral Inspections were made at the following locations: 125, 133, 135, 137 Cobblestone Drive, 118, 155, 162 Buckingham Drive, 1559 Alaqua Drive, and 131, 143 Sweetwater Drive.

Cobblestone Phase 3 and 4 Sewers can be accepted by the Authority.

Duff-Kilbuck Interceptor- the plans have been prepared for the Board of Viewers. As-built lateral locations are prepared.

Kilbuck STP NPDES Update - On August 17, 2012, the PADEP issued a Draft Permit for the NPDES Permit. There is a 30-day review period for comment before the permit is finalized.

Karen Drive – a letter was developed for meeting organization of residents.

Allegheny Co. Health Department – A meeting was held with ACHD regarding review of Operations & Maintenance Plan of Sewerage System.

Sanitary Sewer Cleaning and TV – Insight Pipe Contracting, L.P. has completed sanitary sewer cleaning and TV of approximately 6,700 +/- feet of sanitary sewer. Engineer makes recommendation for payment.

SOLICITOR'S REPORT – It was requested of Mr. Witherel to update the OTSA Rules and Regulations to have property owners be responsible for sewage charges. Mr. Sullivan made a motion, with Mr. Hartle seconded the motion and the motion carried. Mr. Witherel reported he will amend the OTSA Rules and Regulations in reference to property ownership and sewage fees.

ADJOURNMENT – There being no further business to come before the Board, Mr. Hartle made a motion, seconded by Mr. Sullivan, adjourning the meeting. The motion carried unanimously.