

OHIO TOWNSHIP SANITARY AUTHORITY  
MINUTES FROM THE JANUARY 7, 2021 REGULAR MEETING

The Chairman called the Regular Meeting of the Ohio Township Sanitary Authority to order at the Ohio Township Municipal Building at 5:00 p.m. It needs to be noted that due to the Covid-19 pandemic, the Board members attended the meeting via conference call along with Township Solicitor Mike Witherel. Present were: Denny Coyle, Jeff Ciaramella, Herb Hartle, John Sullivan, Rob Trombold, Pat Cannon and Doug Evans.

COMMENTS FROM THE CITIZENS – None.

APPROVAL OF MINUTES – Mr. Trombold made a motion, seconded by Mr. Sullivan approving the December meeting minutes as posted. The motion carried unanimously.

TREASURER'S REPORT & INVOICES DUE FOR PAYMENT – Mr. Sullivan made a motion, seconded by Mr. Trombold, approving the December Treasurer's Report and regular invoices due for payment in the amount of \$72,733.96. The motion carried unanimously.

COMMUNICATIONS – None.

NEW BUSINESS – Mr. Coyle stated we have Resolution No. 1-21 for consideration. This is a resolution for a mutual aid agreement with members of the North Hills Council of Governments. Mr. Hartle made a motion, seconded by Mr. Trombold to approve Resolution No. 1-21. The motion carried.

ENGINEER'S REPORT –

Sewickley Crossing PRD Phase 3 – We have reviewed as-builts and easement exhibits and provided edit requests to Developer. Testing is complete and has passed. Upon execution, we will forward executed easement documents for Authority signatures and completed as-builts to Authority. We expect there to be additional phases. The Engineer recommends adoption of Sewickley Crossing Phase 3 contingent upon receiving proper maintenance bonds from developer. Mr. Trombold made a motion, seconded by Mr. Hartle to accept Sewickley Crossing Phase 3 sewers. The motion carried.

2020 Cleaning & Televising Program – We have forwarded the sewer defect information to Dennis Blakely of MTSA as both defects along McAleer Road are within the jointly owned Bear Run Interceptor.

Nicholson Road Sewer Extension – Easement plats and descriptions are complete.

Grease accumulation at Kilbuck Run STP – Our investigation of grease in the upgradient sewage collection system indicates that TOA at Sewickley Ridge is responsible for a better part of the accumulation. Evidence includes accumulation in wet well of Pump Station #1 at TOA, grease build-up in flat sections of gravity sewer along Duff Road and in manhole invert above Sheetz. The Engineer was requested to schedule a vactor truck for the Kilbuck Run STP.

Alcosan Basin Sewage Tap Requests – We made a request to PA DEP for sewage taps for the period of January 1<sup>st</sup> to June 30<sup>th</sup>, 2021. Until the PA DEP issues new Consent Order with 83 municipalities, requests and PA DEP grant of sewage taps are necessary.

Deduct Meter Inspection – We inspected deduct meter at 105 Gateway Drive (TOA @ Reilly Farm). Deduct meter serves two (2) sprinkler lines at intersection of Gateway and Roosevelt.

SOLICITOR'S REPORT – none.

ADJOURNMENT – There being no further business to come before the Board, Mr. Hartle made a motion, seconded by Mr. Trombold, adjourning the meeting. The motion carried unanimously.

The meeting adjourned at 5:30 P.M. The next monthly meeting will be February 4, 2021 at the newly approved meeting time of 6 pm.